



SMILLIE McADAMS SUMMERLIN LTD.

900 MCKAY ROAD, UNIT 1, PICKERING, ONTARIO, CANADA L1W 3X8 • Phone: (905) 428-6900 • Fax: (905) 428-6598

## SMS PH PROBE MAINTENANCE INSTRUCTIONS

INSPECT PH ELECTRODE ( MODEL 9037 ) AND FLUSH WITH CLEAN WATER TO REMOVE ANY SILT OR DEBRIS.

A PH ELECTRODE WILL PROVIDE ACCURATE AND QUICK RESPONSE READINGS FOR A PERIOD OF 12-18 MONTHS. TO ENSURE A SUITABLE SIGNAL TO THE MONITORING PANEL ( MODEL 47D ), SMS RECOMMENDS SCHEDULED REPLACEMENT OF ELECTRODE ON AN ANNUAL BASIS.

FOR MORE INFORMATION AND TO ORDER PH PROBE CONTACT SMS LTD. PH 905-428-6900, FAX 905-428-6598

NOTE: MOST MUNICIPALITIES ALLOW WASTE WITH A PH BETWEEN APPROXIMATELY 5.5 AND 10. THIS PANEL IS SET TO ALARM AT A PH OF 5.